



**Underwriters
Laboratories Inc.®**

Northbrook Division
333 Pfingsten Road
Northbrook, IL 60062-2096 USA
www.ul.com
tel: 1 847 272 8800
fax: 1 847 272 8129
Customer service: 1 877 854 3577

FEDERAL SIGNAL CORP SIGNAL DIV
MR. LEONARD STEINBEIGLE
2645 FEDERAL SIGNAL DR
UNIVERSITY PARK IL 60466

RE: Project Number(s) - 07NB

Your most recent Certification is shown below. Please review the text and contact the Customer Service Professional who assisted with your project if revisions are required.

To view your company's current Listing Information or for ordering Listing Information in the 3 x 5-inch card format, please refer to www.ul.com.

UGKZ January 7, 2008
Audible-signal Appliances for Use in Hazardous Locations

FEDERAL SIGNAL CORP SIGNAL DIV
2645 FEDERAL SIGNAL DR, UNIVERSITY PARK IL 60466

E12629

Class I, Division 1, Groups B, C, and D; Class I, Division 2, Groups A, B, C, and D; Class II, Division 2, Groups F and G; and Class III.

Audible signal appliances for fire alarm service, Models 304X, 304X-CN+, 314X, 314X-CN+, ASHX, ASHX-CN+, ASUX, ASUX-CN+ when used with Federal Signal's Listed (UGKZ, UGKZC) plug-in module, Models TC-HL, -HN, -WL, -YP, -YW, TM2, UTC or UTM. Suitable for Indoor/Outdoor Use.

Audible signal appliances for general signaling, Models SSTX-MV and SSTX3-MV. Suitable for Indoor/Outdoor Use; ~~Models AM300X#, ++, AM302X#, ++. Suitable for Outdoor, Wet Locations Use.~~

Speakers for fire protective signaling systems, Models 304X, 314X, ASHX and ASUX when used with Federal Signal's Listed (UGKZ, UGKZ7) plug-in module, Models 300CKS, AM25CK, CK25, AM70CK or CK70. Suitable for Indoor/Outdoor Use; ~~Models AM300X, AM302X. Suitable for Outdoor, Wet Locations Use.~~

~~**Speakers for general signaling systems**, Models AM300X, AM302X. Suitable for Outdoor, Wet Locations Use.~~

Class I, Groups B, C and D; Class II, Groups E, F and G; Class III.

Communication center, Model 306MX.

Class I, Groups B, C and D.

Audible signal appliances/speakers, Models 300X, 302X, 304X, 314X, ASHX and ASUX employs plug-in module Models UTM, UTC, TM1, TM2, TM3, TM4, TM5, TM6, TM7, TM8, TM9, TM10, TM11, TM11A, TM12, TM13, TM33, TC-WL, TC-YP, TC-HL, TC-BL, TC-YW, TC-HN, TC-BP, TC-ST, TC-SW, TC-TW, AM25CK, AM70CK, AM100CK, CK25, CK70, EM3, 300CK, T300CK or 300CKS for Indoor/Outdoor Use.

Audible signal appliances, Models SSTX-MV and SSTX3-MV, for Indoor/Outdoor Use.

Speakers, Models AM15XD1, AM30XD1, for Indoor/Outdoor Use. for indoor or outdoor use.

Class I, Groups C and D.

Audible signal appliances/speakers, Models WA410X and WA412X employs plug-in module Models UTM, UTC, TM1, TM2, TM3, TM4, TM5, TM6, TM7, TM8, TM9, TM10, TM11, TM11A, TM12, TM13, TM33, TC-WL, TC-YP, TC-HL, TC-BL, TC-YW, TC-HN, TC-BP, TC-ST, TC-SW, TC-TW, AM25CK, AM70CK, CK25, CK70, EM3, 300CK, T300CK or 300CKS for Indoor/Outdoor Use, Type 4X.

Audible signal appliance/speaker, Model WA408X-MV for Indoor/Outdoor Use, Type 4X.

Class I, Groups C and D; Class II, Groups E, F and G.

Horns, vibrating type, Models 31X, 41X, FHEX for indoor/outdoor use.

Horns, resonating type, Model 55X for indoor/outdoor use.

Siren, electric motor driven, Model AX for indoor/outdoor use.

Class I, Groups A, B, C and D, Division 2; Class II, Groups F and G, Division 2; Class III.

Audible signal appliances/speakers, Models 300GCX, 302GCX, 304GCX, 314GCX, ASHH and ASUH employs plug-in module Models UTM, UTC, TM1, TM2, TM3, TM4, TM5, TM6, TM7, TM8, TM9, TM10, TM11, TM11A, TM12, TM13, TM33, TC-WL, TC-YP, TC-HL, TC-BL, TC-YW, TC-HN, TC-BP, TC-ST, TC-SW, TC-TW, AM25CK, AM70CK, AM100CK, CK25, CK70, EM3, 300CK, T300CK, 300CKS or E300CK, for Indoor/Outdoor Use, Type 4X. Models 300 GCX, 304 GCX and ASHH may be marked IP6X.

Vibrating horn, Model** 350WBX. For indoor/outdoor use; Type 4X.

Audible signal appliances for fire alarm services, Models 304GCX, 304GCX-CN+, 314GCX, 314GCX-CN+, ASHH, ASHH-CN+, ASUH, ASUH-CN+ when used with Federal Signal's Listed (UGKZ, UGKZC) plug-in module, Model TC-HL, TC-HN, TC-WL, TC-YP, TC-YW, TM2, UTC or UTM, suitable for outdoor use.

An independent organization working for a safer world with integrity, precision and knowledge.

148431003



Distributed by Gross Automation | +1 (262) 252-1600 | sales@grossautomation.com

Audible Signal Appliances, general signaling, Models 300GCX and 302GCX when used with Federal Signal's Listed (UGKZ, UGKZC) plug-in module, Model TC-HL, -HN, -WL, -YP, -YW, TM2, UTC or UTM; or Listed (UGKZ, UGKZ7) plug-in module, Model TM33, suitable for outdoor use.

Speakers for fire protective signaling systems, Models 304GCX, 314GCX, ASHH, ASUH when used with Federal Signal's Listed (UGKZ, UGKZ7) plug-in module, Models 300CKS, AM25CK, AM70CK, CK25 or CK70, suitable for outdoor use.

Models AM300GCX, AM302GCX, suitable for outdoor use:

Speakers, general signaling, Models 300GCX and 302GCX when used with Federal Signal's Listed (UGKZ, UGKZ7) plug-in module, Model 300CK, 300CKS, AM25CK, AM70CK, CK25, CK70, E-300CK, EM3 or T-300CK, suitable for outdoor use.

Model AM15XD2++, suitable for outdoor use.

Models ~~AM15XD2, AM300GCX#, ++, AM302GCX#, ++~~, for Indoor/Outdoor Uses, Type 4X. Model AM300GCX may be marked IP6X.

Model* AM310SP for indoor or outdoor use; Type 4X.

Class I, Division 2, Groups A, B, C and D.

Audible Signal subassemblies, plug-in modules, for fire alarm service, Models TC-HL+, TC-HN+, TC-WL+, TC-YP+, TC-YW+, TM-2+, UTC+, and UTM+ for use in Federal Signal's UL Listed SelecTone Series Signal Appliances for hazardous or ordinary locations, suitable for outdoor use. These plug-in modules have been determined to be nonincendive when installed in this manufacturer's SelecTone Series Signal Appliances for Class I, Div. 2, Groups A, B, C and D hazardous locations. They are also suitable for use in this manufacturer's SelecTone Series Signal Appliances for other hazardous locations as specified in the individual Listings.

Audible Signal subassemblies, plug-in modules, general signaling, Model TM33** for use in Federal Signal's UL Listed SelecTone Series Signal Appliances for hazardous or ordinary locations, suitable for outdoor use. These plug-in modules have been determined to be nonincendive when installed in this manufacturer's SelecTone Series Signal Appliances for Class I, Div. 2, Groups A, B, C and D hazardous locations. They are also suitable for use in this manufacturer's SelecTone Series Signal Appliances for other hazardous locations as specified in the individual Listings.

Speaker subassemblies, plug-in modules, for fire alarm service, Models AM25CK, AM70CK, CK25, CK70 and 300CKS for use in Federal Signal's UL Listed SelecTone Series Signal Appliances for hazardous or ordinary locations, suitable for outdoor use. These plug-in modules have been determined to be nonincendive when installed in this manufacturer's SelecTone Series Signal Appliances for Class I, Div. 2, Groups A, B, C and D hazardous locations. They are also suitable for use in this manufacturer's SelecTone Series Signal Appliances for other hazardous locations as specified in the individual Listings.

Speaker subassemblies, plug-in modules, general signaling, Models 300CK, E-300CK, T-300CK and EM3 for use in Federal Signal's UL Listed SelecTone Series Signal Appliances for hazardous or ordinary locations, suitable for outdoor use. These plug-in modules have been determined to be nonincendive when installed in this manufacturer's SelecTone Series Signal Appliances for Class I, Div. 2, Groups A, B, C and D hazardous locations. They are also suitable for use in this manufacturer's SelecTone Series Signal Appliances for other hazardous locations as specified in the individual Listings.

*Also Listed as a Marine Signal Appliance, UXPL.

**Complementary Listed as an Audible Signal Appliance, General Signal.

+ - Complementary Listed under UGKZC.

++ - Complementary Listed under UEAY - Speakers.

- Complementary Listed under UUMW - Speakers and Amplifiers for Fire-Protective Signaling Systems.

LOOK FOR LISTING MARK ON PRODUCT