

# Certificate of Compliance

**Certificate:** 1398389 (LR11170-29)

**Master Contract:** 165016

**Project:** 1398389

**Date Issued:** March 19, 2003

**Issued to:** Federal Signal Corp.  
2645 Federal Signal Dr.  
University Park, IL 60466-3195  
USA

Attention: Ms. Susan Wong

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:** D. Somma, C.E.T.

**Authorized by:** Nick Alfano  
Operations Manager

## PRODUCTS

CLASS 4818 03 - SIGNAL APPLIANCES – Miscellaneous – For Hazardous Locations

Class I, Div. 2, Groups A, B, C and D; Class II, Div. 2, Groups F and G; Class III; Type 4X:  
Intercoms, Models 310X-MV and AD-28X-MV; Rated 24V dc or 120/240V, 50/60Hz, 0.26A max.

## APPLICABLE REQUIREMENTS

CSA Std C22.2 No.	25-1966	- Enclosures for use in Class II, Groups E, F and G Hazardous Locations
CAN/CSA-C22.2 No.	94-M91	- Special Purpose Enclosures
CSA Std C22.2 No.	205-M1983	- Signal Equipment
CSA Std C22.2 No.	213-M198	- Non-Incendive Electrical Equipment for use in Class I, Division2 Hazardous Locations



**Certificate:** 1398389 (LR 11170-29)

**Project:** 1398389

**Master Contract:** 165016

**Date:** March 19, 2003

### **MARKINGS**

Appears on a CSA Certified adhesive-backed label.

- Company Name
- Model Number
- Serial Number
- Electrical Rating
- CSA Monogram
- Hazardous Location Designation
- Special Purpose Enclosure Designation, "Type 4X"
- "Caution: DO NOT DISCONNECT WHILE CIRCUIT IS LIVE UNLESS THE AREA IS KNOWN TO BE NON-HAZARDOUS

**HISTORICAL REFERENCE ONLY**  
Document may not be up to date