



LISTING SERVICE

LISTING No. 7320-0811:0112

Page 1 of 1

CATEGORY: 7320 -- SPEAKERS

LISTEE: Federal Signal, 2645 Federal Signal Drive, University Park, IL 60466-3195
Contact: Sean Moloney (708) 587-3324 Fax (708) 534-4878
Email: smoloney@federalsignal.com

DESIGN: Model AM300 speaker. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 25 or 70 Vrms, 1/2, 1, 2, 7 or 15 Watts

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings and UL label.

APPROVAL: Listed as a speaker for use with separately listed compatible control units. For indoor use only.

If a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition is required, the speaker must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to listee's Installation Instructions Manual for details.

NOTE:

Formerly 7320-0077:038



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **July 01, 2010** Listing Expires **June 30, 2011**

Authorized By: **FRANCIS MATEO, Program Coordinator**
Fire Engineering Division