



# Certificate of Compliance

**Certificate:** 1508771 (LR 5835)

**Master Contract:** 165016

**Project:** 1508771

**Date Issued:** 2004/02/25

**Issued to:** Federal Signal Corporation

2645 Federal Signal Dr  
University Park, IL 60466-3195  
USA

Attention: Susan Wong

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'*



**Issued by:**

Jerry Tang kong

**Authorized by:** Ray Fadavi, P.Eng., MBA,  
Operations Manager

## **PRODUCTS**

CLASS 4812 85 - SIGNAL APPLIANCES - Systems - Certified to US Standards

CLASS 4812 05 - SIGNAL APPLIANCES - Systems

Rotating beacon lights, indoor or outdoor, Type 4X enclosure, 120V, 50/60Hz, Model 121S, 0.36A; Model 121A, 12/24V dc, 3.0A/1.3A; Type 3R enclosure Model 121, 12V dc, 3.0A.

## **APPLICABLE REQUIREMENTS**

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures

CSA Std C22.2 No. 205-M1983 - Signal Equipment

UL Std No. 1638, Fourth Ed. - 2001 - Visual Signalling Appliances - Private Mode Emergency and General Utility Signaling

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.